

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. TN/T/256-2026

Dated: 04.03.2026

It is certified that an inspection team headed by **B. GEORGE, JUNIOR ENGINEER** from **TIRUPPUR TAMILNADU WATER SUPPLY AND DRAINAGE BOARD PHED** inspected the **RASHTRIYA VIDYA BHAVAN, 8/80, CHANAKYA ROAD, SF NO 949/3, PARANJERVALI, NATARPALAYAM PIRIVU, PALAYAKOTTAI ROAD, KANGAYAM, TIRUPUR DISTRICT - 638 701** on 04.03.2026 and on the basis of Water Test Report (Attached) bearing no **TR/2026/070-1** dated 04.03.2026 of **TAMILNADU WATER SUPPLY AND DRAINAGE BOARD DISTRICT WATER TESTING LABORATORY (PHED Lab)** certified that the **RASHTRIYA VIDYA BHAVAN** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 03.03.2027

Signature with Seal:


Junior Water Analyst
District Water Testing Laboratory,
TWAD Board, Tiruppur.

Name: **B. GEORGE**

Designation: **JUNIOR ENGINEER**

Name & Address of the Office / Department: **TAMILNADU WATER SUPPLY AND DRAINAGE BOARD, No. 471 & 472, Bharathiyar Complex, Avinashi Road, Tiruppur - 641602**

To

**RASHTRIYA VIDYA BHAVAN,
8/80, Chanakya Road,
Sf No 949/3, Paranjervali,
Natarpalayam Pirivu,
Palayakottai Road, Kangayam**

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

For **RASHTRIYA VIDYA BHAVAN**



MANAGING DIRECTOR

For **RASHTRIYA VIDYA BHAVAN**



PRINCIPAL



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 471 & 472, Bharathiyar Complex, Avinashi Road,

Tiruppur - 641602.

Phone: 0421 - 2245201

E-mail: labtpr@gmail.com



TC - 15221

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Sample / Lab No:	TR/2026/070-1	Report Issue Date :	04.03.2026
Invoice Details:	3253/Dt.02.03.2026/ Amt.Rs.6,608/-		
ULR No:	TC152212600000069F		

Client Name & Address :
 Contact No / Email.ID : M/s.Rashtriya Vidya Bhavan,
 949/3, Paranjervali, Nattarpalayam Pirivu,
 Palayakottai Road, Kangeyam, Tiruppur Dt- 638 701.

Sample Name : Water- Drinking
 Sample Description : RO Outlet Water
 Sample Code No : 2026 / 070
 Sample Submitted by : Customer- Thiru.M.Arunkumar.
 Location & Date : At M/s.Rashtriya Vidya Bhavan & 02.03.2026.
 Quantity of sample Received : 2 Litre
 Sample Container : Plastic - Good condition.
 Sample Condition on Receipt : Good
 Sample Received On : 02.03.2026
 Test Commenced on : 02.03.2026
 Test Completed on : 03.03.2026
 Environmental Condition : 23.0°C-27.0°C

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25° C	IS 3025 Part 11-2022	--	7.12	6.5-8.5	6.5-8.5
2	Total Alkalinity as CaCO ₃	IS 3025 Part 23-2023	mg/L	40	200	600
3	Total Hardness as CaCO ₃	IS 3025 Part 21-2009 (RA:2023)	mg/L	30	200	600
4	Chloride as Cl	IS 3025-Part 32-1988 (RA:2019)	mg/L	18	250	1000
5	Sulphate as SO ₄	IS 3025-Part 24- Sec 1-2022	mg/L	< 5	200	400
6	Nitrate as NO ₃	IS 3025-Part 34- Sec 1-2023	mg/L	6	45	45
7	Fluoride as F	IS 3025-Part 60- Sec 1-2023	mg/L	< 0.2	1.0	1.5

Remarks : The Tested sample conformed IS:10500:2012 Drinking water specification with respect to above tested Parameters. For RASHTRIYA VIDYA BHAVAN End of the Report.....

(Signature)
 MANAGING DIRECTOR

(Signature)
 For RASHTRIYA VIDYA BHAVAN

Note:

- The test results relate only to the items tested.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
- The result applied to the sample as received basis. For RASHTRIYA VIDYA BHAVAN

Issue No./Date	01/01.07.2024	Amend. No/ Date	60/-	Page No	1 of 1
----------------	---------------	-----------------	------	---------	--------

PRINCIPAL



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 471 & 472, Bharathiyar Complex, Avinashi Road,

Tiruppur – 641602.

Phone: 0421 - 2245201

E-mail: labtpr@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Sample / Lab No:	TR/2026/070-1	Report Issue Date :	04.03.2026
Invoice Details:	3253/Dt.02.03.2026/ Amt.Rs.6,608/-		

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Appearance	Physical observation	--	Clear	-	-
2	Colour	IS 3025-Part 4	Hazen	< 2	5	25
3	Odour	IS 3025-Part 5	--	Agreeable	Agreeable	Agreeable
4	Turbidity	IS 3025-Part 10	NTU	< 0.5	1	5
5	Total Dissolved Solids	IS 3025-Part 16	mg/L	96	500	2000
6	Conductivity	IS 3025-Part 14	µS/cm	137	-	-
7	P – Alkalinity as CaCO ₃	IS 3025–Part 23-1983	mg/L	NIL	-	-
8	Calcium as Ca	IS 3025–Part 40	mg/L	6	75	200
9	Magnesium as Mg	IS 3025–Part 46	mg/L	3	30	100
10	Iron as Fe	IS 3025–Part 53	mg/L	< 0.1	0.3	1
11	Manganese as Mn	IS 3025–Part 59	mg/L	< 0.05	0.1	0.3
12	Ammonia as NH ₃	IS 3025–Part 34	mg/L	< 0.5	0.5	0.5
13	Nitrite as NO ₂	IS 3025–Part 34	mg/L	< 0.01	-	-
14	Total Phosphate as PO ₄	IS 3025–Part 31	mg/L	< 0.1	-	-
15	Residual Chlorine	IS 3025–Part 26	mg/L	< 0.2	0.2	1.0
16	Fecal Coliform	IS 1622	CFU/100ml	0 / 100ml	0 / 100ml	0/100ml

Remarks : The Tested sample conformed IS:10500:2012 Drinking water specification with respect to above tested Parameters.

..... End of the Report....

For RASHTRIYA VIDYA BHAVAN


MANAGING DIRECTOR

For RASHTRIYA VIDYA BHAVAN


PRINCIPAL


District Water Testing Laboratory
Tiruppur

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

Issue No./Date	01/01.07.2024	Amend. No/ Date	00/--	Page No	1 of 1
----------------	---------------	-----------------	-------	---------	--------